

Table 1. Minimum sizes for natural ventilation openings.

Openings are defined in Figure 7.

Use for single or individual spans.

Openings are continuous along building length.

Building Width, BW, ft	Outlet Width, OW, in	Inlet Width, IW, in	Minimum Summer Sidewall Opening, SO, in^a	Minimum Sidewall Height, SH, ft^b
to 20	4-6	2	60	10
22	5-6	3	60	10
24	5-6	3	72	10
26-30	6	3	72	10
32-34	7	4	72	10
36-40	8	4	72	10

^a Recommended opening entire sidewall for summer ventilation.

^b Multi-span structures require 10 to 12 ft. sidewall height.